

The SNMP OIDs for the interSeptor alarms (as required for any monitoring purposes you may wish to run via SNMP) are:

.1.3.6.1.4.1.19011.1.3.1.1.3.2.1.3.1 - Temperature for EMD-1
.1.3.6.1.4.1.19011.1.3.1.1.3.2.1.3.2 - Temperature for EMD-2
.1.3.6.1.4.1.19011.1.3.1.1.3.2.1.5.1 - Humidity for EMD-1
.1.3.6.1.4.1.19011.1.3.1.1.3.2.1.5.2 - Humidity for EMD-2

Please note that all temperature and humidity values are multiplied by ten when retrieved. Therefore the returned values should be divided by ten once retrieved to attain the actual reading.

Alarm 1 : .1.3.6.1.4.1.19011.1.3.1.1.3.2.1.7.1
Alarm 2 : .1.3.6.1.4.1.19011.1.3.1.1.3.2.1.8.1
Alarm 3 : .1.3.6.1.4.1.19011.1.3.1.1.3.2.1.7.2
Alarm 4 : .1.3.6.1.4.1.19011.1.3.1.1.3.2.1.8.2

The values for these OIDs are :

2 : Alarm Disabled
3 : Alarm Active
4 : Alarm Inactive